ECOSTREAM BIOFILTER		
UNIT	FILTER AREA (m^2)	MAX TREATMENT FLOW RATE (L/s)
ES48B	4.459	12.5
ES60B	5.574	15.6
ES72B	6.689	18.7
ES80B	7.432	20.8
ES91B	8.454	23.7
ES96B	8.919	25.0
ES100B	9.290	26.0
ES112B	10.405	29.1
ES120B	11.148	31.2
ES128B	11.892	33.3
ES144B	13.378	37.5
ES160B	14.864	41.6
ES168B	15.608	43.7
ES176B	16.351	45.8
ES225B	20.903	58.5
ES256B	23.783	66.6
ES289B	26.849	75.2
ES324B	30.101	84.3
ES360B	33.445	93.7

INTEGRATED BYPASS			
BASIN	GRATE	BYPASS (L/s)	HEAD REQ. (mm)
375	DOME	45.6	152
		64.6	305
		79.0	457
	FLAT	34.5	152
		49.0	305
		60.0	457
450	DOME	65.7	152
		91.5	305
		113.8	457
	FLAT	43.6	152
		61.7	305
		75.6	457
600	DOME	101.1	152
		143.0	305
		175.3	457
	FLAT	84.1	152
		102.8	305
		126.0	457
750	DOME	133.1	152
		216.6	305
		265.3	457
	FLAT	121.2	152
		171.3	305
		209.8	457

CALCULATIONS BASED ON USDOT/FHWA URBAN DESIGN MANUAL, HYDRAULIC ENGINEERING CIRCULAR NO. 22 THIRD EDITION, PUBLICATION NO FHWA-NHI-10-009, AND A 50% CLOGGING FACTOR.

ECOSTREAM BIOFILTER

- THE ECOSTREAM BIOFILTER IS A BIOFILTRATION STORMWATER TREATMENT TECHNOLOGY THAT RELIES ON PHYSICAL, CHEMICAL AND BIOLOGICAL MECHANISMS TO REMOVE TOTAL SUSPENDED SOLIDS, TOTAL PHOSPHORUS, TOTAL NITROGEN, HEAVY METALS, OIL AND GREASE, TRASH AND BACTERIA.
- THE SITE DESIGN ENGINEER MUST REVIEW ELEVATIONS AND FINALIZE GRADING TO MEET SITE CONDITIONS.
- THE SITE DESIGN ENGINEER MUST REVIEW THE INLET CHANNEL AND FINALIZE THE DESIGN TO MEET SITE CONDITIONS.
- WATER SURFACE ELEVATION ESTIMATED BASED ON THE INLET CAPACITY OF THE NYLOPLAST GRATE AND THE PROVIDED BYPASS FLOW RATE PER THE SITE DESIGN ENGINEER. SITE DESIGN ENGINEER MUST REVIEW THE WATER SURFACE ELEVATION AND FINALIZE THE DESIGN TO MEET THE PROJECT DESIGN PARAMETERS.
- ADS DOES NOT DESIGN OR PROVIDE MEMBRANE LINERS. TO MINIMIZE THE LEAKAGE POTENTIAL OF LINER SYSTEMS, THE MEMBRANE LINER SYSTEM SHOULD BE DESIGNED BY A KNOWLEDGEABLE GEOTEXTILE PROFESSIONAL AND INSTALLED BY A QUALIFIED CONTRACTOR.
- ADS DOES NOT RECOMMEND PLACING THE LINED ECOSTREAM SYSTEM IN THE WATER TABLE. FOR ASSISTANCE PLEASE CONTACT ADS.



PLAN VIEW
NTS



PROFILE VIEW
NTS

ECOSTREAM BIOFILTER
LINER INSTALLATION OPTION
BASIC MEDIA

DATE: 05/21/26 DRAWN: JLM
DRAWING #: 571-010_C CHECKED: TD/AT/PR

DATE	DWN	CHK

EcoStream™ Biofilter
Stormwater Media Filters

4640 TRUEMAN BLVD
HILLIARD, OH 43026

THIS DRAWING IS NOT INTENDED FOR USE IN BIDDING OR CONSTRUCTION WITHOUT THE EOR'S PRIOR APPROVAL. EOR SHALL REVIEW THIS DRAWING PRIOR TO BIDDING AND/OR CONSTRUCTION. IT IS THE ULTIMATE RESPONSIBILITY OF THE EOR TO ENSURE THAT THE PRODUCT(S) DEPICTED AND ALL ASSOCIATED DETAILS MEET ALL APPLICABLE LAWS, REGULATIONS, AND PROJECT REQUIREMENTS.
THIS DRAWING HAS BEEN PREPARED BASED ON INFORMATION PROVIDED TO ADS/STORMTECH UNDER THE DIRECTION OF THE PROJECT'S ENGINEER OF RECORD ("EOR") OR OTHER PROJECT REPRESENTATIVE. THIS DRAWING IS NOT INTENDED FOR USE IN BIDDING OR CONSTRUCTION WITHOUT THE EOR'S