

## Section 2723

### Engineered Surface Drainage Products

#### GENERAL

PVC surface drainage inlets shall be of the curb inlet structure type as indicated on the contract drawings and referenced within the contract specifications. The **ductile iron frame, grate and hood** for each of these structures are to be considered an integral part of the surface drainage inlet and shall be furnished by the same manufacturer. The curb inlet structure shall be as manufactured by Nyloplast a division of Advanced Drainage Systems, Inc. or prior approved equal.


#### MATERIALS

The curb inlet structure required for this contract shall be manufactured from PVC pipe stock, utilizing a thermo-molding process to reform the pipe stock to the specified configuration. The drainage pipe connection stubs shall be manufactured from PVC pipe stock and formed to provide a watertight connection with the specified pipe system. This joint tightness shall conform to ASTM D3212 for joints for drain and sewer plastic pipe using flexible elastomeric seals. The flexible elastomeric seals shall conform to ASTM F477. The pipe bell spigot shall be joined to the main body of the structure. The raw material used to manufacture the pipe stock that is used to manufacture the main body and pipe stubs of the surface drainage inlets shall conform to ASTM D1784 cell class 12454.

The grate, frame and hood for all curb inlet structures shall be ductile iron and shall be made specifically for each so as to provide a round bottom flange that closely matches the diameter of the PVC structure body. The grate, frame and hood shall be capable of supporting H-20 wheel loading for traffic areas. The hood section will have a solid back and be adjustable by use of three (3) locking hex head bolts. The metal used in the manufacture of the castings shall conform to ASTM A536 grade 70-50-05 for ductile iron.

#### INSTALLATION

The specified PVC surface drainage inlet shall be installed using conventional flexible pipe backfill materials and procedures. The backfill material shall be crushed stone or other granular material meeting the requirements of class 1, class 2, or class 3 material as defined in ASTM D2321. Bedding and backfill for the curb inlet structure shall be placed and compacted uniformly in accordance with ASTM D2321. The curb inlet structure body will be cut at the time of the final grade. No brick, stone or concrete block will be required to set the grate to the final grade height. For H-20 load rated installations, a concrete ring will be poured under the frame, grate, and hood. The concrete slab must be designed taking into consideration local soil conditions, traffic loading, and other applicable design factors. For other installation considerations such as migration of fines, ground water, and soft foundations refer to ASTM D2321 guidelines.

THIS PRINT DISCLOSES SUBJECT MATTER IN WHICH NYLOPLAST HAS PROPRIETARY RIGHTS. THE RECEIPT OR POSSESSION OF THIS PRINT DOES NOT CONFER, TRANSFER, OR LICENSE THE USE OF THE DESIGN OR TECHNICAL INFORMATION SHOWN HEREIN REPRODUCTION OF THIS PRINT OR ANY INFORMATION CONTAINED HEREIN, OR MANUFACTURE OF ANY ARTICLE HEREFROM, FOR THE DISCLOSURE TO OTHERS IS FORBIDDEN, EXCEPT BY SPECIFIC WRITTEN PERMISSION FROM NYLOPLAST. ©2013 NYLOPLAST	DRAWN BY	CJA	MATERIAL		 3130 VERONA AVE BUFORD, GA 30518 PHN (770) 932-2443 FAX (770) 932-2490 www.nyloplast-us.com
	DATE	03-10-00	PROJECT NO./NAME		
	REVISED BY	NMH			TITLE 2 FT X 2 FT & 2 FT X 3 FT CURB INLET STRUCTURE SPECIFICATIONS
	DATE	03-10-16	DWG NO.      7002-110-005      REV    H		
DWG SIZE	A	SCALE			1:1