



Nominal Diameter, ID, in. (mm)	Depth of Invert, H, in. (mm)	
	Minimum	Maximum
4 (100)	10.75 (273)	28.50 (724)
6 (150)	13.00 (330)	30.50 (775)
8 (200)	15.00 (381)	32.50 (826)
10 (250)	17.00 (432)	34.50 (876)
12 (300)	19.50 (495)	48.50 (1232)
15 (375)	22.50 (572)	51.50 (1308)
18 (450)	25.50 (648)	54.50 (1384)
24 (600)	31.75 (806)	60.50 (1537)
30 (750)	38.75 (984)	66.50 (1689)
36 (900)	44.75 (1137)	72.50 (1842)

**NOTES:**

1. BACKFILL DESIGN SHOULD BE USED FOR H-10 LOADING APPLICATIONS.
2. SITE ENGINEER TO PROVIDE SITE SPECIFIC DETAILS, SUCH AS CONCRETE STRENGTH.
3. REFER TO ADS TECH NOTE 1.01 FOR PERFORATION INFORMATION.
4. REFER TO ADS TECH NOTE 2.11 FOR ADDITIONAL DESIGN INFORMATION.

© 2023 ADS, INC.

REV.	DESCRIPTION	BY	MM/DD/YY	CHK'D
0	-	-	-	-

ADVANCED DRAINAGE SYSTEMS, INC. ("ADS") HAS PREPARED THIS DETAIL BASED ON INFORMATION PROVIDED TO ADS. THIS DRAWING IS INTENDED TO DEPICT THE COMPONENTS AS REQUESTED. ADS HAS NOT PERFORMED ANY ENGINEERING OR DESIGN SERVICES FOR THIS PROJECT, NOR HAS ADS INDEPENDENTLY VERIFIED THE INFORMATION SUPPLIED. THE INSTALLATION DETAILS PROVIDED HEREIN ARE GENERAL RECOMMENDATIONS AND ARE NOT SPECIFIC FOR THIS PROJECT. THE DESIGN ENGINEER SHALL REVIEW THESE DETAILS PRIOR TO CONSTRUCTION. IT IS THE DESIGN ENGINEERS RESPONSIBILITY TO ENSURE THE DETAILS PROVIDED HEREIN MEETS OR EXCEEDS THE APPLICABLE NATIONAL, STATE, OR LOCAL REQUIREMENTS AND TO ENSURE THAT THE DETAILS PROVIDED HEREIN ARE ACCEPTABLE FOR THIS PROJECT.

Duraslot Recharge Installation

DRAWING NUMBER: STD-1465A



4640 TRUEMAN BLVD  
HILLIARD, OHIO 43026

DRAWN BY:	KJS
DATE:	07-05-2023
CHK'D BY:	
SCALE:	NTS
SHEET:	1 OF 1