



LIFTING STRAP
(TYPICAL)




TOP VIEW


TANK EXTERIOR	
LENGTH	50.9 [1,293]
WIDTH	50.9 [1,293]
HEIGHT	50.5 [1,283]




Ⓢ MID-HEIGHT SEAM SECTION DETAIL



SECTION A - A'



END VIEW



ISOMETRIC VIEW

NOTES:

1. ALL DRAWING DIMENSIONS IN INCHES [MILLIMETERS] OR AS NOTED.
2. EXTERIOR OF ACCESS OPENING LID INCLUDES THE FOLLOWING WARNING IN ENGLISH, FRENCH & SPANISH: "DANGER DO NOT ENTER: POISON GASES."
3. TANK MARKINGS INCLUDE: MANUFACTURER NAME, MODEL NUMBER, LIQUID CAPACITY, DATE OF MANUFACTURE CODE, MAXIMUM BURIAL DEPTH, INLET, AND OUTLET.
4. MAXIMUM BURIAL DEPTH IS 52 in [1,321 mm].
5. MINIMUM BURIAL DEPTH IS 6 in [152 mm].
6. TANK IS FOR NON-TRAFFIC APPLICATIONS.
7. NOMINAL WALL THICKNESS IS 0.2 in [5 mm].



INFILTRATOR WATER TECHNOLOGIES, LLC
4 BUSINESS PARK RD, OLD SAYBROOK, CT 06475
WWW.INFILTRATORWATER.COM
PHONE: (800) 221-4436 / EMAIL: INFO@INFILTRATORWATER.COM

IM-Tank

IM-300
PUMP TANK CONFIGURATION

DRAWN BY
EA
DATE
05/12/2025
SCALE
NTS
SHEET NO.
01 of 01