



TOP VIEW



P PIPE PENETRATION SECTION DETAIL




S MID-HEIGHT SEAM SECTION DETAIL


| TANK EXTERIOR | |
|---------------|--------------|
| LENGTH | 127.0 [3226] |
| WIDTH | 62.2 [1580] |
| HEIGHT | 54.7 [1389] |

| | |
|--------------|-------------|
| LIQUID DEPTH | 44.0 [1118] |
| INVERT DROP | 3.0 [76] |
| FREEBOARD | 10.2 [260] |


| | |
|----------------|-------------------|
| TOTAL CAPACITY | 1287 GAL [4872 L] |
| WORKING VOLUME | 1094 GAL [4141 L] |



SECTION A - A'




END VIEW



SECTION B - B'

NOTES:

1. ALL DRAWING DIMENSIONS IN INCHES [MILLIMETERS] OR AS NOTED.
2. EXTERIOR OF ACCESS OPENING LID INCLUDES THE FOLLOWING WARNING IN ENGLISH, FRENCH & SPANISH: "DANGER DO NOT ENTER: POISON GASES."
3. TANK MARKINGS WILL INCLUDE: MANUFACTURER NAME, MODEL NUMBER, LIQUID CAPACITY, DATE OF MANUFACTURE, MAXIMUM BURIAL DEPTH, INLET, AND OUTLET.
4. MAXIMUM BURIAL DEPTH IS 48 in [1219 mm].
5. MINIMUM BURIAL DEPTH IS 6 in [152 mm].
6. TANK IS FOR NON-TRAFFIC APPLICATIONS.
7. AIRSPACE IS 16.5%.
8. OUTLET TEE IS COMPATIBLE WITH AN EFFLUENT FILTER.
9. INTERIOR LENGTH TO WIDTH RATIO IS 2.3:1 (118.8-INCH LENGTH / 51.7-INCH WIDTH = 2.3).



ISOMETRIC VIEW



IM-Tank

INFILTRATOR WATER TECHNOLOGIES, LLC
 4 BUSINESS PARK RD, OLD SAYBROOK, CT 06475
 WWW.INFILTRATORWATER.COM
 PHONE: (800) 221-4436 / EMAIL: INFO@INFILTRATORWATER.COM

INFILTRATOR IM-1060 TANK
 1-COMPARTMENT CONFIGURATION

DRAWN BY
 EA
 DATE
 05/12/2025
 SCALE
 NTS
 SHEET NO.
 01 of 02