



NOTES:

1. VENT MAY BE CONNECTED THROUGH ANY CHAMBER CORRUGATION CREST.
2. VENT MAY BE ALSO BE CONNECTED THROUGH END CAP OR AS PERFORATED PIPE THROUGH STONE.
3. ALL SCHEDULE 40 FITTINGS TO BE SOLVENT CEMENTED.

4840 TRUEEMAN BLVD
HILLIARD, OH 43026



StormTech®
Chamber System

**OPTIONAL VENT DETAIL
STORMTECH**

DATE:	05/01/25	DRAWN:	SMW
DRAWING #:		720-030 C	CHECKED: JLM

THIS DRAWING HAS BEEN PREPARED BASED ON INFORMATION PROVIDED TO ADSTORMTECH UNDER THE DIRECTION OF THE PROJECTS ENGINEER OF RECORD (EOR) OR OTHER PROJECT REPRESENTATIVE. THIS DRAWING IS NOT INTENDED FOR USE IN BIDDING OR CONSTRUCTION WITHOUT THE EOR'S PRIOR APPROVAL. EOR SHALL REVIEW THIS DRAWING PRIOR TO BIDDING AND/OR CONSTRUCTION. IT IS THE ULTIMATE RESPONSIBILITY OF THE EOR TO ENSURE THAT THE PRODUCT(S) DEPICTED AND ALL ASSOCIATED DETAILS MEET ALL APPLICABLE LAWS, REGULATIONS, AND PROJECT REQUIREMENTS.