


INJECTION MOLDED REDUCING TEE
6" x 4" - 10"x8" - 12"x8" DIAMETER

PART #	PIPE SIZE	A	B	JOINT
0660ST	6 × 4 in (150 × 100 mm)	7.4 in (187 mm)	4.4 in (111 mm)	ST
0660WT	6 × 4 in (150 × 100 mm)	7.4 in (187 mm)	4.4 in (111 mm)	WT
1062ST	10 × 8 in (250 × 200 mm)	17.9 in (454 mm)	9.9 in (252 mm)	ST
1062WT	10 × 8 in (250 × 200 mm)	17.9 in (454 mm)	9.9 in (252 mm)	WT
1262WT	12 × 8 in (300 × 200 mm)	22.5 in (572 mm)	13.6 in (346 mm)	WT




NOTE:

FITTINGS WHOSE PART NUMBERS END WITH "WT" HAVE WATER TIGHT BELL CONNECTIONS. WATER TIGHT BELLS ARE SHOWN HERE IN THIS DRAWING AND REQUIRE GASKETS TO BE FITTED TO DUAL WALL PIPE TO FORM A WATER TIGHT JOINT. (GASKETS INCLUDED)

FITTINGS WHOSE PART NUMBERS END WITH "ST" HAVE SOIL TIGHT BELL CONNECTIONS. SOIL TIGHT BELLS HAVE MOLDED CLEATS AND REQUIRE NO GASKET TO MAKE CONNECTION TO DUAL WALL PIPE.

NOTE: ALL FITTINGS DIMENSIONS ARE FOR REFERENCE ONLY

© 2023 Advanced Drainage Systems, Inc.

	DRAWING #:	3010	
	DRAWN BY:	JCB	04.24.07
	APPROVED BY:		
	REVISIONS:	TJR	10.17.07