

PIPE SIZE	PIPE OD	"A" MIN. HOLE Ø	MIN. DISTANCE FROM PIPE INVERT TO STRUCTURE INVERT	ADS PRODUCT CODE
12" (300mm)	14.5" (368mm)	19.50" (495mm)	3.7" (94mm)	1202PS
15" (375mm)	17.6" (447mm)	23.00" (584mm)	4.0" (102mm)	1502PS
18" (450mm)	21.4" (544mm)	26.50" (673mm)	4.2" (107mm)	1802PS
24" (600mm)	27.8" (706mm)	33.25" (845mm)	4.5" (114mm)	2402PS
30" (750mm)	35.1" (892mm)	40.50" (1029mm)	5.2" (132mm)	3002PS
36" (900mm)	41.1" (1044mm)	47.00" (1194mm)	5.5" (140mm)	3602PS
42" (1050mm)	47.7" (1212mm)	53.00" (1346mm)	5.7" (145mm)	4202PS
48" (1200mm)	53.6" (1361mm)	59.00" (1499mm)	5.7" (145mm)	4802PS
60" (1500mm)	66.3" (1684mm)	72.00" (1829mm)	6.4" (163mm)	6002PS

NOTES:


- PERFORMANCE HIGHLY DEPENDENT ON INSTALLATION. CONTRACTOR MUST ENSURE MANHOLE GASKET IS UNIFORMLY SEATED AROUND STRUCTURE ADAPTER. EXTRA PRECAUTIONS MUST BE TAKEN TO PREVENT DIFFERENTIAL SETTLEMENT BETWEEN THE PIPE AND MANHOLE. INSTALLATION RECOMMENDATIONS ARE ALSO SPECIFIED IN INSTALLATION GUIDE 1.05: WATERSTOP INSTALLATION.
- SEE STANDARD DETAIL STD-201 AND WATERSTOP INSTALLATION GUIDE FOR INSTALLATION RECOMMENDATIONS.
- PIPE JOINTS SHOULD BE A MINIM OF 3 FT. FROM STRUCTURE CONNECTION
- PIPE BELLS TO BE COMPLETELY REMOVED BEFORE MAKING CONNECTION
- COMPLETELY FILL INTERNAL VOID SPACE WITH NON-SHRINK GROUT OR MASONRY & MORTAR

© 2026 ADS, INC

5	CONNECTION DETAILS UPDATE	RKC	3/5/26	CJD
REV.	DESCRIPTION	BY	MM/DD/YY	CHK'D

ADVANCED DRAINAGE SYSTEMS, INC. ("ADS") HAS PREPARED THIS DETAIL BASED ON INFORMATION PROVIDED TO ADS. THIS DRAWING IS INTENDED TO DEPICT THE COMPONENTS AS REQUESTED. ADS HAS NOT PERFORMED ANY ENGINEERING OR DESIGN SERVICES FOR THIS PROJECT, NOR HAS ADS INDEPENDENTLY VERIFIED THE INFORMATION SUPPLIED. THE INSTALLATION DETAILS PROVIDED HEREIN ARE GENERAL RECOMMENDATIONS AND ARE NOT SPECIFIC FOR THIS PROJECT. THE DESIGN ENGINEER SHALL REVIEW THESE DETAILS PRIOR TO CONSTRUCTION. IT IS THE DESIGN ENGINEERS RESPONSIBILITY TO ENSURE THE DETAILS PROVIDED HEREIN MEETS OR EXCEEDS THE APPLICABLE NATIONAL, STATE, OR LOCAL REQUIREMENTS AND TO ENSURE THAT THE DETAILS PROVIDED HEREIN ARE ACCEPTABLE FOR THIS PROJECT.

12"-60" HP STORM WATERSTOP MH/CATCH BASIN CONNECTION	
DRAWING NUMBER:	STD-206A

 <small>Advanced Drainage Systems, Inc.</small>	4640 TRUEMAN BLVD HILLIARD, OHIO 43026	DRAWN BY: JAB
		DATE: 4/3/09
		CHK'D BY:
		SCALE: NTS
		SHEET: 1 OF 1